

浅川清流環境組合可燃ごみ処理施設

環境監視日報

2020年4月1日

令和2年7月4日
クリーンセンター連絡協議会
浅川清流環境組合

| 項目 | 1号炉 | | | | |
|----|------|-------|-------|--------------------|---------------------|
| | 塩化水素 | 窒素酸化物 | 硫黄酸化物 | ばいじん | 水銀 |
| | ppm | ppm | ppm | g/m ³ N | μg/m ³ N |
| | 10 | 20 | 10 | 0.005 | 50 |
| 時間 | 430 | 250 | 約2700 | 0.040 | 50 |
| 1 | 6 | 8 | 2 | 0 | 0 |
| 2 | 6 | 10 | 3 | 0 | 0 |
| 3 | 6 | 11 | 2 | 0 | 0 |
| 4 | 6 | 10 | 2 | 0 | 0 |
| 5 | 6 | 11 | 2 | 0 | 0 |
| 6 | 6 | 9 | 2 | 0 | 0 |
| 7 | 6 | 12 | 2 | 0 | 0 |
| 8 | 6 | 10 | 2 | 0 | 0 |
| 9 | 6 | 11 | 2 | 0 | 0 |
| 10 | 6 | 8 | 2 | 0 | 0 |
| 11 | 6 | 11 | 2 | 0 | 0 |
| 12 | 6 | 10 | 3 | 0 | 0 |
| 13 | 6 | 13 | 2 | 0 | 0 |
| 14 | 6 | 11 | 2 | 0 | 0 |
| 15 | 6 | 10 | 2 | 0 | 0 |
| 16 | 6 | 10 | 2 | 0 | 0 |
| 17 | 6 | 10 | 2 | 0 | 0 |
| 18 | 6 | 10 | 2 | 0 | 0 |
| 19 | 6 | 11 | 3 | 0 | 0 |
| 20 | 6 | 12 | 3 | 0 | 0 |
| 21 | 6 | 9 | 3 | 0 | 0 |
| 22 | 6 | 10 | 4 | 0 | 0 |
| 23 | 6 | 8 | 4 | 0 | 0 |
| 24 | 6 | 8 | 4 | 0 | 0 |

自主規制値
法規制値

| 項目 | 2号炉 | | | | |
|----|------|-------|-------|--------------------|---------------------|
| | 塩化水素 | 窒素酸化物 | 硫黄酸化物 | ばいじん | 水銀 |
| | ppm | ppm | ppm | g/m ³ N | μg/m ³ N |
| | 10 | 20 | 10 | 0.005 | 50 |
| 時間 | 430 | 250 | 約2700 | 0.040 | 50 |
| 1 | 6 | 10 | 2 | 0 | 2 |
| 2 | 6 | 11 | 2 | 0 | 2 |
| 3 | 6 | 10 | 2 | 0 | 1 |
| 4 | 6 | 8 | 2 | 0 | 2 |
| 5 | 6 | 13 | 1 | 0 | 1 |
| 6 | 6 | 9 | 1 | 0 | 1 |
| 7 | 6 | 10 | 1 | 0 | 1 |
| 8 | 6 | 12 | 1 | 0 | 3 |
| 9 | 6 | 11 | 1 | 0 | 3 |
| 10 | 6 | 12 | 1 | 0 | 2 |
| 11 | 6 | 8 | 2 | 0 | 2 |
| 12 | 6 | 14 | 1 | 0 | 2 |
| 13 | 6 | 11 | 1 | 0 | 1 |
| 14 | 6 | 10 | 1 | 0 | 2 |
| 15 | 6 | 12 | 1 | 0 | 1 |
| 16 | 6 | 12 | 1 | 0 | 1 |
| 17 | 6 | 9 | 1 | 0 | 1 |
| 18 | 6 | 10 | 1 | 0 | 1 |
| 19 | 6 | 10 | 2 | 0 | 1 |
| 20 | 6 | 9 | 2 | 0 | 1 |
| 21 | 6 | 12 | 2 | 0 | 1 |
| 22 | 6 | 8 | 3 | 0 | 1 |
| 23 | 6 | 12 | 2 | 0 | 1 |
| 24 | 6 | 10 | 3 | 0 | 1 |

環境監視日報

2020年4月2日

| 項目 | 1号炉 | | | | |
|----|------|-------|-------|--------------------|---------------------|
| | 塩化水素 | 窒素酸化物 | 硫黄酸化物 | ばいじん | 水銀 |
| | ppm | ppm | ppm | g/m ³ N | μg/m ³ N |
| | 10 | 20 | 10 | 0.005 | 50 |
| 時間 | 430 | 250 | 約2700 | 0.040 | 50 |
| 1 | 6 | 11 | 4 | 0 | 0 |
| 2 | 6 | 7 | 3 | 0 | 0 |
| 3 | 6 | 12 | 3 | 0 | 0 |
| 4 | 6 | 10 | 3 | 0 | 0 |
| 5 | 6 | 9 | 3 | 0 | 0 |
| 6 | 6 | 13 | 3 | 0 | 0 |
| 7 | 6 | 6 | 3 | 0 | 0 |
| 8 | 6 | 12 | 3 | 0 | 0 |
| 9 | 6 | 10 | 3 | 0 | 0 |
| 10 | 6 | 11 | 3 | 0 | 0 |
| 11 | 6 | 8 | 3 | 0 | 0 |
| 12 | 6 | 11 | 3 | 0 | 0 |
| 13 | 6 | 11 | 3 | 0 | 0 |
| 14 | 6 | 9 | 3 | 0 | 0 |
| 15 | 6 | 12 | 4 | 0 | 0 |
| 16 | 6 | 10 | 3 | 0 | 1 |
| 17 | 6 | 11 | 3 | 0 | 1 |
| 18 | 6 | 9 | 4 | 0 | 1 |
| 19 | 6 | 13 | 4 | 0 | 1 |
| 20 | 6 | 10 | 4 | 0 | 3 |
| 21 | 6 | 2 | 2 | 0 | 2 |
| 22 | 6 | 11 | 3 | 0 | 1 |
| 23 | 6 | 10 | 4 | 0 | 3 |
| 24 | 6 | 11 | 4 | 0 | 2 |

自主規制値
法規制値

| 項目 | 2号炉 | | | | |
|----|------|-------|-------|--------------------|---------------------|
| | 塩化水素 | 窒素酸化物 | 硫黄酸化物 | ばいじん | 水銀 |
| | ppm | ppm | ppm | g/m ³ N | μg/m ³ N |
| | 10 | 20 | 10 | 0.005 | 50 |
| 時間 | 430 | 250 | 約2700 | 0.040 | 50 |
| 1 | 6 | 11 | 3 | 0 | 1 |
| 2 | 6 | 8 | 3 | 0 | 1 |
| 3 | 6 | 10 | 2 | 0 | 1 |
| 4 | 6 | 11 | 2 | 0 | 1 |
| 5 | 6 | 11 | 2 | 0 | 1 |
| 6 | 6 | 8 | 2 | 0 | 1 |
| 7 | 6 | 8 | 2 | 0 | 1 |
| 8 | 6 | 12 | 2 | 0 | 1 |
| 9 | 6 | 9 | 2 | 0 | 1 |
| 10 | 6 | 11 | 2 | 0 | 1 |
| 11 | 6 | 9 | 2 | 0 | 1 |
| 12 | 6 | 9 | 3 | 0 | 1 |
| 13 | 6 | 13 | 2 | 0 | 1 |
| 14 | 6 | 10 | 3 | 0 | 1 |
| 15 | 6 | 11 | 3 | 0 | 1 |
| 16 | 6 | 9 | 3 | 0 | 1 |
| 17 | 6 | 9 | 2 | 0 | 1 |
| 18 | 6 | 13 | 2 | 0 | 1 |
| 19 | 6 | 12 | 2 | 0 | 1 |
| 20 | 6 | 10 | 2 | 0 | 1 |
| 21 | 6 | 14 | 2 | 0 | 1 |
| 22 | 6 | 10 | 2 | 0 | 0 |
| 23 | 6 | 14 | 2 | 0 | 1 |
| 24 | 6 | 12 | 2 | 0 | 1 |